



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx SIR 06.0086U Issue No: 3 Certificate history:
Status: **Current** Page 1 of 4 Issue No. 3 (2014-05-20)
Date of Issue: **2014-05-20** Issue No. 2 (2012-10-09)
Applicant: **ABTECH Limited** Issue No. 1 (2010-07-28)
Sanderson Street Issue No. 0 (2006-10-25)
Lower Don Valley
Sheffield S9 2UA
United Kingdom

Electrical Apparatus: **BPG Range of Enclosures**
Optional accessory:

Type of Protection: **Increased safety, intrinsically safe and dust**

Marking: Ex ia IIC Ga Ex e IIC Gb Ex ib IIC Gb
Ex ta IIIC Da IP6X Ex tb IIIC Db IP6X Ex tb IIIC Db IP6X

Approved for issue on behalf of the IECEx
Certification Body:

C Ellaby

Position:

Deputy Certification Manager

Signature:
(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

SIRA Certification Service
Rake Lane
Eccleston
Chester
CH4 9JN
United Kingdom

sira
CERTIFICATION



IECEX Certificate of Conformity

Certificate No: IECEx SIR 06.0086U Issue No: 3
Date of Issue: 2014-05-20 Page 2 of 4
Manufacturer: **ABTECH Limited**
Sanderson Street
Lower Don Valley
Sheffield S9 2UA
United Kingdom

Additional Manufacturing
location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition:6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-11 : 2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-26 : 2006 Edition:2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga
IEC 60079-31 : 2008 Edition:1	Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'
IEC 60079-7 : 2006-07 Edition:4	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[GB/SIR/ExTR06.0100/01](#) [GB/SIR/ExTR12.0245/00](#) [GB/SIR/ExTR13.0296/00](#)

Quality Assessment Report:

[GB/SIR/QAR06.0046/00](#) [GB/SIR/QAR06.0046/01](#) [GB/SIR/QAR06.0046/04](#)
[GB/SIR/QAR06.0046/05](#) [GB/SIR/QAR06.0046/06](#)



IECEx Certificate of Conformity

Certificate No: IECEx SIR 06.0086U

Issue No: 3

Date of Issue: 2014-05-20

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The BPG range of enclosures are manufactured in various sizes from glass reinforced polyester, with or without anti-static carbon loading. The enclosures consists of a main body and a detachable or hinged lid. Refer to the Annexe of this certificate for a full description.

CONDITIONS OF CERTIFICATION: NO



IECEx Certificate of Conformity

Certificate No: IECEx SIR 06.0086U

Issue No: 3

Date of Issue: 2014-05-20

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Issue 1 – this Issue introduced the following changes:

1 To allow GB/SIR/ExTR06.0100/01 to replace GB/SIR/ExTR06.0100/00

Issue 2 – this Issue introduced the following changes:

1 The Description was aligned with certificate no. Sira 99ATEX3172U associated with this enclosure, this included recognising the following changes assessed as part of that certificate.

* The BPG 13.5 enclosure was added to the range.

* The option to fit slotted trunking inside the enclosures, this trunking may be sited as required. The instructions were modified to recognise additional restrictions associated with this change and a new Condition of Manufacture was introduced.

* The recognition of minor drawing modifications including the introduction of a new company logo; these amendments are administrative or involve changes to the design that do not affect the aspects of the product that are relevant to explosion safety.

2 Following appropriate re-assessment to demonstrate compliance with the requirements of the latest standards, the documents previously used for assessment were replaced by those currently listed, the markings were updated accordingly. In addition, the enclosure was allowed to be used for intrinsically safe applications and IEC 60079-11:2012 Edition 6 was included in the list of supporting standards.

3 The Description of Component and Condition of Certification were amended to recognise that closed cell polychloroprene gaskets are no longer used.

4 The Condition of Certification and the Special Point for Noting related to static were both removed; in addition, a Schedule of Limitations was added and the Conditions of Certification were rationalised to bring them into line with Sira 99ATEX3172U.

Issue 3 – this Issue introduced the following changes:

1. Using IEC 60079-26, the enclosures were allowed to be marked with 'Ex ia' and 'Ex ta' concepts for EPL levels Ga and Da.

2. The introduction of one or more optional Earth Bars. Each earth bar is manufactured from copper or The introduction of one or more optional Earth Bars. Each earth bar is manufactured from copper or brass, which may optionally be plated, and are mounted and fixed to at least two welded pillars, welded studs, or internal earth mounting plate (if fitted). Each earth bar is connected to the main internal earth point of the enclosure in which it is fitted. Individual earth connection is made via a threaded entry using a screw and self locking nut, or screw and nut and anti-vibration washer, or locked via the use of thread sealant, and designed to accept a crimped conductor lug. This change necessitated the introduction of new Conditions of Certification.

3. It was recognised that, when not manufactured with anti-static carbon loading, the BPG range of empty enclosures are not suitable for portable use, therefore the Schedule of Limitations was modified.

Annex:

[06-0086U_Issue3 Annexe.pdf](#)