

Certificate of Assessment

- 1 Component **SX Range of enclosures
BPG Range of enclosures
BPGC Range of enclosures**
- 2 Manufacturer **Abtech Ltd**
- 3 Address **2 Sanderson Street
Lower Don Valley
Sheffield
S9 2UA**
- 4 The components specified have been assessed against the requirements of the standard specified in Section 7.
- 6 This evaluation is based on the following certificate documents:
IECEX SIR 05.0046U SX Range of enclosures
IECEX SIR 06.0086U BPG and BPGC Range of enclosures
- 7 Specification: **EN 62262:2002** (IEC 62262:2002)
- 8 Impact level: **IK08**
- 9 Assessment:
The products listed in Section 1 have been tested under more onerous conditions, with a 25 mm impact head. The test reports are recorded in the certification listed in Section 6.
- 10 Date: 1 October 2013

