

## Certificate of Assessment

- 1 Component **SX Range of enclosures**  
**BPGC Range of enclosures**
- 2 Manufacturer **Abtech Ltd**
- 3 Address **2 Sanderson Street**  
**Lower Don Valley**  
**Sheffield**  
**S9 2UA**
- 4 The components specified have been assessed against the requirements of the standard specified in Section 7.
- 6 This evaluation is based on the following certificate documents:  
IECEX SIR 05.0046U SX Range of enclosures  
IECEX SIR 06.0086U BPGC Range of enclosures  
Tests carried out on 7 October 2013
- 7 Specification: **EN 62262:2002** (IEC 62262:2002)
- 8 Impact level: **IK09**
- 9 Assessment:  
The products listed in Section 1 have been tested under more onerous conditions, with a 25 mm impact head. The test results are recorded in the project file.
- 10 Date: 7 October 2013

