

## Certificate of Compliance

Issued to:

AB CONTROLS & TECHNOLOGY LIMITED (ABTECH)

**IP67 VERSIONS IN EITHER STAINLESS STEEL OR** Apparatus: PAINTED MILD STEEL OF THE FOLLOWING ENCLOSURES: \$45,\$64,\$66,\$X0,\$X0.5,\$X1,\$X1.5,\$X2,\$X3,\$X4,\$X5,\$X0(200),\$X0.5(200), SX1(200), SX1.5(200), SX2(200), SX3(200), SX4(200) & SX5(200)

This is to certify that a sample of the equipment defined above has been type tested by ERA Technology Limited and found to comply with the following requirements:

ERA Document Reference DTS 01: 1991 Test Schedule for Electrical Equipment to be Installed in Areas Subject to Water **Deluge Systems** 

Full details are given in Report No. 5046/370 dated February 1995

Certificate prepared by Canal Market

**Technician** 

Certificate approved by Chruch

Manager

Certificate No 5046/C370 Dated 2nd March 1995 GDL2/C0958